



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1913

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd, part of the Kiwa UK Group

This is to certify that

PA. Charalambous Trading Co. Ltd

**Industrial Zone Polis Chrysochous
PO Box 66120
Polis Chrysochous
Pafos, Cyprus
Tel: +357 26 323250**

Who fabricate the following timber fire doors and or doorsets:

**Halspan EI30, EI30Sa, Halspan EI60, EI60Sa.
Strebord EI30, EI30Sa, Strebord EI60, EI60Sa.**

have satisfied the requirements of the SDP 01 Fire Resistant Timber Door scheme. This includes the testing of products to **EN1634-1** the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes integrity & insulation** are detailed on page 2 of this certificate.

Initial Certification: 04 April 2024

Valid to: 03 April 2029

Issue number: 1

David Mowatt
Head of Certification – IFC Certification /
KIWA Group Limited

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



The production of fire-resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Doorset Description	Fire Rating	Assessment/Test Report
Halspan 30	30 minutes	BMT/CNA/F13020
Halspan 60	60 minutes	BMT/FEA/F13021
Strebord 44	30 minutes	BMT/CNA/F14053
Strebord 54	60 minutes	BMT/CNA/F14054

Signed on behalf of Kiwa UK

David Mowatt
Head of Certification – IFC Certification /
KIWA Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder’s responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.

CERTIFICATE

